

2024 Annual Drinking Water Quality Report

Camelot Lakes & Camelot East Parks

PWS 6584439



This report has been prepared by Novak Environmental Services to inform you about the quality of your drinking water and the excellent services that are delivered to you every day.

Camelot's drinking water source is from wells located on the Camelot property. These wells draw from "The Intermediate Aquifer". Camelot purifies all of the water drawn from these wells at a reverse osmosis water treatment facility located on the property. This water is also disinfected and aerated prior to entering the distribution system.

The Department of Environmental Protection has performed a Source Water Assessment on our system and the search of the data sources indicated no potential sources of contamination near our wells. The results from this assessment are available on the DEP Source Water Assessment and Protection Program website at [www.dep.state.fl.us.swapp](http://www.dep.state.fl.us/swapp).

If you have any questions regarding this report or concerning your water utility, please contact Jim Novak with Novak Environmental Services at 941-716-1835. We want our valued customers to be informed about their water utility. If you would like additional copies of this report, please inquire at the Camelot office.

The schedule for homeowners meetings is located on the bulletin board in the clubhouse, all homeowners are encouraged to attend.

We at Camelot work around the clock to provide our customers top quality water to every tap. We ask that all our customers help us protect our water sources, as these water sources are an invaluable part of our everyday life.

We are pleased to report that our drinking water meets all federal and state requirements. □

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas productions, mining or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. River Vista WTP is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact River Vista WTP, Laura Novak at 941-716-4025. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

these terms we have provided the following definitions:

ND: The target analyte was not detected.

PPM (parts per million): one part by weight of analyte to 1 million parts by weight of the water samples. (One part per million corresponds to one penny in \$10,000)

PPB (parts per billion): One part by weight of analyte to one billion parts by weight of the water sample. (One ppb corresponds to one penny in \$10,000,000)

PC/L (Picocuries per liter): Picocuries per liter is a measure of the radioactivity in water.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique: A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MRDL (Maximum Residual Disinfection Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfection Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Camelot Utilities routinely monitors for contaminants in your drinking water according to Federal and State laws, rules and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1st, 2024 to December 31st, 2024. As authorized by the EPA, the State of Florida has reduced monitoring requirements for certain contaminants. Some of the data, though representative, is more than one year old. All results in this report are from the most recent testing.

This drinking water quality table only includes the contaminants that were detected. Many more contaminants may have been tested for but were not detected. These contaminants are not listed in the table.

2024 Water Quality Summary

Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium ppm	7/2024	No	0.0047	n/a	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Sodium ppm	7/2024	No	20.9	n/a	n/a	160	Salt water intrusion, leaching from soil
Nitrate ppm	7/2024	No	0.04	n/a	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Fluoride ppm	7/2024	No	0.24	n/a	5	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm
Mercury ppb	7/2024	No	.19	n/a	.14	.14	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland

Radioactive Contaminants

Contaminants and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Radium 226 pCi/L	6/2021	No	1.92	n/a	5	5	Erosion of natural deposits
Gross Alpha pCi/L	7/2024	No	6.16	n/a	15	15	Erosion of natural deposits

Lead and Copper Monitoring (Tap Water)

Contaminant	Collection Date	AL Exceeded (Y/N)	90 th Percentile Result	No. of Sampling sites exceeding the AL	Range of Tap Sample Results	MCLG	AL (Action Level)	Likely Source of Contamination
Copper ppm	7/2024	No	0.46	Zero sites above the action level	0.006-0.10	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead ppb	7/2024	No	0.6	Zero sites above the action level	0.00025-0.00073	0	15	Corrosion of household plumbing systems and service lines connecting buildings to water mains; erosion of natural deposits

Detected Compound	Sample Collection Date	MCL Violation (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Haloacetic Acids							
East Clubhouse (HAA5) (ppb)	07/2024	No	10.7	N/A	N/A	60	Byproduct of drinking water disinfection

Total Trihalomethanes							
East Clubhouse (TTHM) (ppb)	07/2024	No	57.9	N/A	N/A	80	Byproduct of drinking water disinfection

Detected Compound	Sample Collection Date	MCL Violation (Y/N)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Haloacetic Acids							
Lakeside Clubhouse (HAA5) (ppb)	07/2024	No	27.5	N/A	60	60	Byproduct of drinking water disinfection

Total Trihalomethanes							
Lakeside Clubhouse (TTHM) (ppb)	07/2024	No	61.7	N/A	80	80	Byproduct of drinking water disinfection